

The following is an AWU update on Leak Related work during the fiscal year of 09/10.

- In April of 2010 AWU completed hiring the staff for a Second Shift. This shift begins at 3:30 pm and works until mid-night, Monday through Friday. Leaks reported from mid-night to 7:30 am Saturday and Sunday's are covered through an On Call System.
- Leak Detection;

Contracted Leak Detection Services

1. Investigated 15,040 main line valves for leaks
2. Investigated 7,380 fire hydrants for leaks
3. Investigated 720 miles (3,801,600 linear feet ) of pipe line for leaks
4. Investigations performed found 121 leaks

AWU in House Crews

1. Investigated 5,028 linear feet of main
2. Investigations performed found 20 leaks

- Water Main Rehabilitation

	LF Completed	LF in Construction	LF Bidding	LF in Design
Fy Yr 08/09	4,621 lf	30,647 lf	13,040 lf	185,400 lf
Fy Yr 09/10	21,326 lf	36,256 lf	10,549 lf	179,253 lf

- Leak Response

Minor Leaks Repaired requiring no follow up Work Orders to be generated

	24 hours or less	Greater than 24 hours	Total Leaks
FY 08/09	2,431	1,174	3,605
FY 09/10	5,145	38	5,183

Leaks Repaired requiring a Work Order and repair crew

	FY 08/09	FY 09/10
Same Day Repair	490	1,005
1 Day Repair	514	642
2-3 Day Repair	338	130
Greater than 3 Day	807	117
Totals	2,149	1,894