

Line Extension – Practices, Costs, and Policy




Larry Weis, Austin Energy General Manager Austin City Council Committee – AE August 13, 2013 **Mission:** Deliver clean, affordable, reliable energy and excellent customer service.



- Understanding the AE distribution system
- Annual CIP spending
- Line extension policies and practices
- Other utilities, Contribution in Aid of Construction, and regulatory policies
- Control electric rates
- Recommendations and potential impacts of policy changes



Distribution System Overview






AE Distribution System

- Distribution system consists of primarily 12,500 volt feeders and equipment from substation to the customer's meter
- Dense distribution network built across 437 square mile service area
 - > Typically no new line or substation built for single residence, apartment complex or mixed use development
- As overall demand exceeds capacity of infrastructure, AE expands system to ensure reliability
 - > Distribution system improvements may include a new substation or transformer, new three phase lines
 - > Supports existing and future customers

Distribution System Map



Light Blue – Underground

Item #22

Dark Blue – Overhead



Distribution Assets

• General Distribution System – 5,400 MVA


- > 59 distribution substations
- > 78,715 distribution transformers
- > 5,403 miles overhead
- > 5,995 miles underground

Unique Assets

- > Downtown network two substations, 450 MVA
 - Single vault on customer site may serve multiple customers
- > Dedicated industrial services 567 MVA
 - Redundant services paid for by customers



Distribution Spending







Line Extension Policies & Cost Recovery

- What Is Contribution In Aid of Construction (CIAC)?
 - > Nonrefundable contribution paid by a customer
 - > Plant funded by CIAC not included in base rates
 - > No standard CIAC/line extension policy in Texas



Typical Customer Costs

- Majority of new customer connections are underground
- Customer builds and pays for civil work on property
 - > Includes equipment pads, trenching, conduit, and subsurface structures
- AE assumes ownership of civil facilities after they pass inspection for AE's use
- Civil represents at least 50% of total cost
- Cost is not paid for by AE, so it is not included in revenue requirements used to set rates



Additional Costs to Customer


- Additional money collected for:
 - > Excess facilities requested by customer
 - > Underground electric service equipment (ex. switchgear)
 - > Dual feed & primary metered services
 - > Replacement/relocation of existing facilities on or adjacent to customer site at customer request
 - > After hours work requested by customer
 - > Temporary power
 - Installation of all temporary facilities
 - Removal of all temporary facilities
 - > Some fees subject to 15% mark up as defined in fee schedule



Single Family Subdivision

- 55 units, average 3,000 square feet
- Installed eight pad mount transformers and 4,100' underground cable
- Total project cost = \$108,704.20 (including transformers)
- 300' allowance per meter = \$181,178.30
- Projected revenue allowance = \$46,763.64
- Developer contribution = \$0 to AE; transfer all civil infrastructure to AE
- Estimated civil construction cost = \$124,000
- Cost per unit: AE \$1,976; developer \$2,255








Apartment Development

- 352 units, average 800 square feet
- Installed 15 pad mount transformers and 8,800' underground cable
- Total project cost = \$178,894.97 (including transformers)
- 300' allowance per meter = \$1,159,540.80
- Projected revenue allowance = \$97,521.06
- Developer contribution = \$0 to AE; transfer all civil infrastructure to AE
- Estimated Civil Construction Cost = \$232,000
- Cost per unit: AE \$508; developer \$659






Network Project

- 135 units, average 750 square feet
- Installed three network transformers and 8,100' network cable
- Total project post = \$385,193.54 (including transformers)
- 300' allowance per meter = \$988,245.00
- Projected revenue allowance = \$32,807.43
- Developer contribution = \$0 to AE; transfer all civil infrastructure to AE
- Estimated civil construction cost = \$1,100,000
- Cost per unit: AE \$2,853; developer \$8,148







Examples of AE Project Costs

- Residential
 - > Single family subdivision, town home, & condo developments
 - > New construction on vacant lots
 - > Additional residential units on already served lots
 - > Average total cost: \$3,000/meter

Apartment Complexes

- > Moderately dense load
- > Existing parcels repurposed to meet City growth objective
- > May include mixed use with a commercial component
- > Average total cost: \$750/meter
- Network
 - > Very dense load
 - > Requires specialized equipment which increases cost
 - > Average total cost: \$3,000/meter
- Commercial & Industrial
 - > Customer specific load requirements
 - > Higher revenue through demand charges
 - > Average total cost: \$16,000/meter



Area Utilities Policies and Fees

Utility	CIAC Policy Summary		
Pedernales Electric Cooperative	CIAC = (Direct Cost + System Cost) – (Annual Revenue/Return Factor)		
Bluebonnet Electric Cooperative	Residential CIAC = Total Cost – (\$1,200/service) Commercial CIAC = Total Cost – (\$350/service)		
Oncor Electric Delivery	CIAC = Direct Cost – Standard Allowance + Tax Liability + Franchise Fees Standard Allowance Factors: Secondary Service > 10kw - \$155/kW Primary Service > 10 kW - \$79/kW 300' Allowance for Residential Customers		
Austin Energy	CIAC = Total Cost (excl. transformers & services) – Allowance (cost of 300 feet/customer & 20% of 3 year revenue)		
CPS Energy	Extends Distribution System at Its Discretion		



Line Extension Fees Collected

- AE typically budgets a credit of \$6 million for CIAC 30% of total budgeted for new services
 - On-site customer work to relocate AE facilities
 - Costs above standard OH service
 - Cost of excess facilities needed to meet customer's business needs beyond basic service
- Most new services constructed in Austin are underground; developer installs civil which is at least 50% of the total cost of new electric service
- With CIAC and civil work by customer, they typically contribute 50-75% of the new service cost (under current policy)



Complexity of Collecting More

- Need more robust accounting system for customers to pay additional cost for on-site and portion of system improvements
- New system would capture system improvement costs for allocation to new users and actual job costs for customers who prefer to pay actual vs. estimated cost
- Significant impact on overall construction costs will lead to increased real estate and rental costs



Recommendations

- Implement new fee of \$100 per Electric Service Planning Application to be collected when electric permit is issued
- Carefully consider timing and impact of policy changes to ensure consistency with COA economic development and growth strategies
- Policy should limit financial risk to utility and current customers, but not stifle economic development or result in relocation to less desirable areas
- Policy changes should be easily calculated by customers, staff, and developers



Proposed Policy Comparison

Service Request Category	Current CIAC Collection	Proposed CIAC Collection	
Overhead	\$0 unless exceeding 300 feet allowance	5 year period to phase up to 75% of all costs including transformers	
Underground Residential	Civil work by customer; Excess facilities charges	Civil work by customer; 5 year period to phase up to 75% of all costs including transformers	
Network	Civil work by customer; Excess facilities charges	Civil work by customer; 5 year period to phase up to 75% of all costs including transformers	
Commercial	Civil work by customer; Excess facilities charges	Civil work by customer; 5 year period to phase up to 75% of all costs including transformers	
Industrial/Primary	Negotiated	Negotiated	



Implementation

- Proposed start date: October 2014
- Ramped up collection of CIAC:

Fiscal Year	2015	2016	2017	2018	2019
CIAC %	15%	30%	45%	60%	75%

- Policy changes within AE to support estimated or actual charges
- Staffing increase within AE to accommodate additional work functions, customer concern mitigation, and meet customer time tables
- Austin Energy will need software systems to facilitate efficient work flow

Item #22



Questions?

