

C27
/1

**PLANNING COMMISSION SITE PLAN
CONDITIONAL USE PERMIT REVIEW SHEET**

CASE NUMBER: SPC-2014-0091A **PLNNG. COMM. DATE:** 8-26-2014

ADDRESS: 508 E. Oltorf

WATERSHED: Blunn Creek (Urban)

AREA: 2472 s.f.

EXISTING ZONING: GO-NP

NEIGHBORHOOD PLAN: Greater South River City Combined

PROJECT NAME: 508 E. Oltorf

PROPOSED USE: Limited restaurant (Coffee shop)

OWNER: 508 E. Oltorf LLC (Jimmy Nassour)
3839 Bee Caves Rd., Ste. 200
Austin, TX 78746
(512) 474-2900

AGENT: Carlson Comm'l. Properties, LLC (Steve Portnoy)
3839 Bee Caves Rd., Ste. 200
Austin, TX 78746
(512) 474-2900

NEIGHBORHOOD ORGANIZATION:

- 511- Austin Neighborhoods Council
- 1200- Super Duper Neighborhood Objectors
and Appealers organization
- 1037- Homeless Neighborhood Assn.
- 498- South Central Coalition
- 74- South River City Citizens Assn.
- 1075- League of Bicycle Voters
- 1360- Zoning Committee of South River City Citizens
- 1185- Greater SRCC Nghbrhd Planning Team

APPLICABLE WATERSHED ORDINANCE: Current/ Comprehensive watershed ordinance

CAPITOL VIEW: Not in View Corridor

SUMMARY STAFF RECOMMENDATION: Recommended.

PLANNING COMMISSION ACTION: 8-26-2014

CASE MANAGER: Lynda Courtney, 974-2810

C27/2

PROJECT INFORMATION:

EXIST. ZONING: GO-NP
SITE AREA: .3874 Acres
EXIST. USE: Office
PROP. USE: Office and Lmted. Restaurant
IMPERV. COVER EXIST: 17,464 SF (94.9%)
IMPERV. COVER PROPOSED: 17,457 (94.9%)
IMPERV. COVER MAXIMUM: 80%
PARKING REQUIRED: 17 Spaces
PARKING PROVIDED: 23 Spaces

BLDG. HT.: 25' (60' Max. allowed)
FAR: .18 (1:1 Max)
BLDG. CVRG: 13% (60% Max.)

SUMMARY COMMENTS ON SITE PLAN:

The applicant is requesting a conditional use permit for the conversion of a portion of an existing building to a limited restaurant use (Proposed coffee shop), which is conditionally permitted in GO zoning.

The existing building, previously used as medical and general office use, will be renovated internally to allow for a coffee shop use on the bottom floor (744 SF) and an office on the top floor (2472 SF). A small deck seating area will be added over existing impervious cover on the lower level.

SURROUNDING CONDITIONS:

Zoning/ Land use

North: SF-3-NP, Single family Residential
South: Oltorf St., then MF-6-CO-NP, Multifamily, and SF-2-NP, Religious Assembly
East: Rebel Rd., then CS-NP, Auto sales
West: LR-NP, Retail

C21/3

CONDITIONAL USE PERMIT REVIEW AND EVALUATION CRITERIA

The following evaluation is included to provide staff position on each point of the conditional use permit criteria. Section 25-5-145 of the Land Development Code states: "The Commission shall determine whether the proposed development or use of a conditional use site plan complies with the requirements of this section.

A conditional use site plan must:

1. Comply with the requirements of this title; **Staff response: This application complies with the requirements of this title.**
2. Comply with the objectives and purposes of the zoning district; **Staff response: This application complies with the objectives and purposes of the zoning district. A limited restaurant is a conditionally-permitted use in GO zoning.**
3. Have building height, bulk, scale, setback, open space, landscaping, drainage, access, traffic circulation, and use that is compatible with the use of an abutting site; **Staff response: This application falls within the regulations of the Land Development Code and is compatible with the uses of abutting sites.**
4. Provide adequate and convenient off-street parking and loading facilities; **Staff response: Adequate and convenient off-street parking are provided, meeting the minimum parking requirements for a limited restaurant. No loading facilities are proposed.**
5. Reasonably protect persons and property from erosion, flood, fire, noises, glare, and similar adverse effects; **Staff response: The site does not contribute to any of these adverse effects.**

A Conditional Use Site Plan May Not:

1. More adversely affect an adjoining site than would a permitted use; **Staff response: This site plan conforms to all regulations and standards established by the Land Development Code for its proposed use and zoning. This site plan does not more adversely affect an adjoining site than would the existing use or a regularly permitted use.**
2. adversely affect the safety or convenience of vehicular or pedestrian circulation, including reasonably anticipated traffic and uses in the area; **Staff response: This is not anticipated to any detriment of safety or convenience.**
3. adversely affects an adjacent property or traffic control through the location, lighting, or type of signs; **Staff response: No signage or lighting is proposed that would affect adjacent properties or traffic control.**

508 EAST OLTORF COFFEE SHOP CONDITIONAL USE PERMIT

Index To Sheets


- 1. CVI COVER SHEET
- 2. FP FINAL PLAN
- 3. ER1 EXISTING CONDITIONS MAP
- 4. SPT SITE PLAN
- 5. SP2 GENERAL DETAILS & NOTES
- 6. AS1 EXTERIOR ELEVATIONS/COMPATIBILITY SECTION
- 7. AS2 EXTERIOR ELEVATIONS/COMPATIBILITY SECTION

Watershed: Blue Creek (Ubaou)
Pressure Zone: Central South (CSI)
Ordinance: C14-00-0139 (South River City Neighborhood Plan)
MAFSCO Grid No: H10 J19
MAFSCO Page No: 614Y.615S
FEMA Map: 4845300983R1, Dated September 26, 2008
Zoning: CO-NP
TCBQ Recharge Zone: NO
COA Recharge Zone: NO



APPROVED FOR APPROVAL
MARCH 10, 2014
SPC-2014-0091A

REVIEWED BY: _____ DATE: _____
PLANNING AND DEVELOPMENT REVIEW DEPARTMENT



Address: 508 EAST OLTORF

Legal Description:
Lot 2, Deedfield Subdivision
A Subdivision in Travis County, Texas
According to the Map or Plat Recorded
in Volume 16, Page 67 of the Plat Records
of Travis County, Texas

Owner/Architect:
B&G Surveying, Inc.
1404 West North Loop Blvd.
Austin, TX 78756
Phone: (512) 411-2300
Contact: Steve Porisoy

Architect:
Dick Clark & Associates
207 W. 4th Street
Austin, TX 78701
Phone: (512) 472-4980
Contact: Mark Vornberg

Revisions / Corrections


NO	DESCRIPTION	DATE	BY	CHKD BY



Handwritten signature: *CCZ*

ICC LONGARO & CLARKE
Consulting Engineers
Lead Development @ Stormwater Management @ Water Resources
3000 Bee Crr Road, Ste. 120 - Austin, Texas 78746
800.500.0228 - www.LongaroClarke.com - IRE Reg. No. F-34

2008-24 - 308 E. ANGELO - CIVIL - 1/20

NOTES:
1. REVIEWER OF THIS PERMITTING CASES ARE CONSTRUCTIVE & NON-COMPLIMENTARY. THE REVIEWER IS NOT RESPONSIBLE FOR THE COMPLETION, ACCURACY AND RELIABILITY OF THE PERMITTING APPLICATION OR THE PERMITTING PROCESS BY THE APPLICANT.
2. ALL RESPONSIBILITY FOR THE ACCURACY OF THESE PLANS REMAINS WITH THE ENGINEER WHO PREPARED THEM. IT IS APPROVED UNDER THE CITY OF AUSTIN'S SEAL ONLY WHEN THE ENGINEER OF THESE PLANS BY THE CITY OF AUSTIN ADOPTS COMPLIANCE WITH APPLICABLE CITY REGULATIONS ONLY. APPROVAL BY OTHER PROFESSIONAL ENTITIES MAY BE OBTAINED FOR THESE PLANS THROUGH THE CITY OF AUSTIN'S PERMITTING PROCESS. DETERMINING WHAT ADDITIONAL APPROVALS ARE NECESSARY.
3. EXISTING UTILITIES ARE SHOWN AND DEPICTED. CONSULTING SHALL VERIFY ACCORDING TO EXISTING RECORDS FROM THE UTILITIES TO BE INSTALLED OR EXISTING UTILITIES TO BE REMOVED OR CHANGED.
4. UNDEVELOPED STORMWATER - THIS PROJECT IS LOCATED IN THE MAINTAINED MAINTENANCE ZONE. UNDEVELOPED STORMWATER SHALL BE STORED IN THE MAINTAINED MAINTENANCE ZONE. UNDEVELOPED STORMWATER SHALL BE STORED IN THE MAINTAINED MAINTENANCE ZONE. UNDEVELOPED STORMWATER SHALL BE STORED IN THE MAINTAINED MAINTENANCE ZONE.
5. THE SITE IS NOT LOCATED WITHIN THE MAINTAINED MAINTENANCE ZONE.



 Subject Tract
 Base Map

CASE#: SPC-2014-0091A
 ADDRESS: 516 E. Oltorf Street



This product is for informational purposes and may not have been prepared for or be suitable for legal, engineering, or surveying purposes. It does not represent an on-the-ground survey and represents only the approximate relative location of property boundaries.

This product has been produced by the Planning and Development Review Department for the sole purpose of geographic reference. No warranty is made by the City of Austin regarding specific accuracy or completeness.

Courtney, Lynda

From: Couch, Amanda
Sent: Thursday, July 10, 2014 4:07 PM
To: Joseph Longaro
Cc: Courtney, Lynda; 'steve. portnoy'; Mark Vornberg; Jain, Sangeeta
Subject: RE: 508 E. Oltorf Coffee Shop - SPC-2014-0091A



Joe,

TR1 is cleared.

Staff will recommend the CUP with the following conditions:

1. the head-in, back-out parking along Rebel Road is removed,
2. the drive aisle on Rebel Road closest to Oltorf Street is closed, and
3. a sidewalk, built to Urban Roadway standards is constructed along Rebel Road.

Staff considers the current layout of the parking and drive aisle to be a safety hazard to the additional foot traffic that will be generated by the new use. Please contact me with any questions.

Thank you,

..

Amanda M. Couch
Senior Planner

City of Austin
Planning and Development Review Department, Land Use Review
505 Barton Springs Road, 4th Floor, Austin, Texas 78704
(512)974-2881

Supervisor:
Sangeeta Jain
Sangeeta.Jain@austintexas.gov

From: Joseph Longaro [redacted]
Sent: Thursday, July 10, 2014 2:01 PM
To: Couch, Amanda
Cc: Courtney, Lynda; 'steve. portnoy'; Mark Vornberg
Subject: 508 E. Oltorf Coffee Shop - SPC-2014-0091A

Amanda

Pursuant to our meeting on Tuesday July 8th, 2014 we have addressed your comment TR1 in that the ADA routing shown on the site plan does cross over onto the proposed Deck and as such an ADA Ramp is not needed, as the ADA route on the site plan is shown correctly

In regard to the remaining comments, you indicated you would be discussing the remaining items with the transportation team. Can you please let us know the status of

this and if all is cleared, there are no reaming comments and as such we would like to be scheduled for the Next Planning Commission Hearing.

Thank you

Joe

Joseph Longaro, P.E.
President
Longaro & Clarke, L.P.
3839 Bee Caves Road, Suite 150
Austin, Texas 78746
PH 512-306-0228
Mob 512-784-8722
Email Joe@longaroclarke.com
www.longaroclarke.com



CITY OF AUSTIN – PLANNING AND DEVELOPMENT REVIEW DEPARTMENT
SITE PLAN APPLICATION – MASTER COMMENT REPORT

CASE NUMBER: **SPC-2014-0091A**
REVISION #: **00**
CASE MANAGER: **Lynda Courtney**

UPDATE: **U1**
PHONE #: **512-974-2810**



PROJECT NAME: **508 E Oltorf Coffee Shop**
LOCATION: **516 E OLTORF ST**

SUBMITTAL DATE: **June 20, 2014**
REPORT DUE DATE: **July 7, 2014**
FINAL REPORT DATE: **July 7, 2014**

STAFF REPORT:

This report includes all staff comments received to date concerning your most recent site plan submittal. The comments may include requirements, recommendations, or information. The requirements in this report must be addressed by an updated site plan submittal.

The site plan will be approved when all requirements from each review discipline have been addressed. However, until this happens, your site plan is considered disapproved. Additional comments may be generated as a result of information or design changes provided in your update.

If you have any questions, problems, concerns, or if you require additional information about this report, please do not hesitate to contact your case manager at the phone number listed above or by writing to the City of Austin, Planning and Development Review Department, P.O. Box 1088, Austin, Texas 78704.

UPDATE DEADLINE (LDC 25-5-113):

It is the responsibility of the applicant or his/her agent to update this site plan application. **The final update to clear all comments must be submitted by the update deadline, which is September 17, 2014.** Otherwise, the application will automatically be denied. If this date falls on a weekend or City of Austin holiday, the next City of Austin workday will be the deadline.

EXTENSION OF UPDATE DEADLINE (LDC 25-1-88):

You may request an extension to the update deadline by submitting a written justification to your case manager on or before the update deadline. Extensions may be granted for good cause at the Director's discretion.

UPDATE SUBMITTALS:

An informal update submittal is required. You must submit the distribution to the case manager.

Please submit 2 copies of the plans and 2 copies of a letter that address each comment for distribution to the following reviewers. Clearly label information or packets with the reviewer's name that are intended for specific reviewers. No distribution is required for the Planner 1 and only the letter is required for Austin Water Utility.

REVIEWERS:

Planner 1 : Natalia Rodriguez
Site Plan : Lynda Courtney
Transportation : Amanda Couch

Environmental Review - Pamela Abee-Taulli - 512-974-1879

UPDATE 1 July 1, 2014

Please be advised that additional comments may be generated as update information is reviewed. If an update has been rejected, reviewers are not able to clear comments based on phone calls, emails, or meetings, but must receive formal updates in order to confirm positive plan set changes.

C29
/10

General Notes Sheet

EV 1-6 UPDATE 1 Comments revoked. Thank you.

EV 7 UPDATE 1 Comment cleared. Thank you.

EV 8 UPDATE1 You may absolutely defer this to the construction phase. My comment was not appropriate for the Part A application. Thank you.

Fire For Site Plan Review - James Reeves - 512-974-0193

Approved

Site Plan Review - Lynda Courtney - 512-974-2810

SP1. Comment addressed.

SP2. Comment addressed.

SP3. Comment addressed.

SP 4. FYI--This site plan requires a conditional use permit because the use, Limited Restaurant, is conditionally permitted in GO zoning. When all substantive staff comments are addressed, this project will be scheduled for public hearing and approval before Planning Commission. An additional notification of the surrounding neighbors, property owners and overlapping neighborhood associations will be required prior to this public hearing, and an additional notification fee will be required at that time.

SP5. FYI- FLASH DRIVE—Upon approval of this site plan, a flash drive will be required to be submitted to be scanned into the City of Austin database.

Transportation Review - Amanda Couch - 512-974-2881

TR1. Accessible routes within the boundary of the site must be provided from public transportation stops, accessible parking and passenger loading zones, and public streets or sidewalks to the accessible building entrance they serve. [IBC1104.1]. Provide accessible routes in accordance with TAS standards.

U1: Show ramp where ADA route traverses over the proposed wood deck.

C27
11

- TR2. ***U1: Comment cleared.***
- TR3. ***U1: Comment cleared.***
- TR4. ***U1: Comment cleared.***
- TR5. ***U1: Comment cleared.***
- TR6. ***U1: Comment cleared.***
- TR7. ***U1: Comment cleared.***
- TR8. Show the location of 4 foot sidewalks according to City Standards along Rebel Road .
LDC, Sec. 25-6-352; TCM, 4.2.1.
U1: Comment pending discussion with the transportation team.
- TR9. The standard location for a sidewalk is between the curb line and property line, 2 feet off the property line. Show this dimension on the site plan. Meandering sidewalks are encouraged in order to avoid trees or other natural features. Sidewalks adjacent to the curb are not allowed unless approved by the transportation reviewer. TCM, 4.2.1, 4.2.2.
U1: Comment pending discussion with the transportation team.
- TR10. Raised curbs on driveways must terminate at sidewalks. Indicate the termination of curbs and show the standard driveway detail. Do not show curb ramps at the driveway. TCM, 5.3.1.E; COA Std. No. 433-2.
U1: Comment pending discussion with the transportation team.
- TR11. Head-in, back-out parking is prohibited on streets and alleys in SF-6 and more permissive districts, unless approved by the Transportation reviewer. LDC, 25-6-472; TCM, 5.3.1.F.
U1: Comment pending discussion with the transportation team.