Address:	3910 Glengarry Dr.
Permit Number:	2015-061453
Property Owner Requesting Special Exception:	Richard Haenke

Special Exception Requested:
Deck located in PUE
Date Structure was originally constructed: verified to exist in 1984 as per expired permit in COA system

Date of Inspection:	5-17-2015
Building Official or designated representative	Tony Hernandez

The granting of the variances requested will <u>Not</u> result in any hazard to the life, health or public safety for either the property for which the variance is requested or to an adjoining public or private property



The granting of the variances request will result in a hazard to the life, health or public safety of the either the property for which the variance is requested or to an adjoining public or private property. The following hazards related to the variance request were noted in this inspection:

- 1. Needs engineer to verify structural integrity of deck
- 2. Pool barrier needs to comply with code requirements. Fence is creating ladder effect