

# AGENDA



## Recommendation for Council Action

Austin City Council	Item ID	47840	Agenda Number	61.
---------------------	---------	-------	---------------	-----

Meeting Date:	8/20/2015	Department:	Watershed Protection
---------------	-----------	-------------	----------------------

### Subject

Conduct a public hearing and consider an ordinance regarding a floodplain variance for the construction of a new duplex at 1006 Payne Avenue, which is partially located in the 25-year and 100-year floodplains of the Grover Tributary of Shoal Creek (District 7).

### Amount and Source of Funding

### Fiscal Note

There is no unanticipated fiscal impact. A fiscal note is not required.

Purchasing Language:	
Prior Council Action:	
For More Information:	Kevin Shunk, 512-974-9176; Mapi Vigil, 512-974-3384
Council Committee, Boards and Commission Action:	
MBE / WBE:	
Related Items:	

### Additional Backup Information

The property owner proposes to demolish the existing single-family building and construct a new, two-story 3,253 square foot duplex with a 229 square foot attached garage and a 249 square foot attached carport. The property is partially located in the 25-year and 100-year floodplains of the Grover Tributary of Shoal Creek. While the proposed duplex will not encroach into the 25-year or 100-year floodplains, the development would not satisfy the safe access requirement of the floodplain regulations. The development is the subject of Residential Plan Review application number: 2015-043204 PR.

The owner is seeking variances to the City of Austin's floodplain management regulations to not provide normal access from the building to an area that is a minimum of one foot above the design flood elevation. A summary of the depth of water during the 100-year and 25-year flood events can be found below:

Depth of water:	100-year flood event	25-year flood event
At the street	1.4 ft.	1.0 ft.

**THE WATERSHED PROTECTION DEPARTMENT RECOMMENDS DENIAL OF THIS VARIANCE REQUEST.**