

# PROJECT FACT SHEET – Home Depot Data Center

<b>Property Name</b>	Home Depot Data Center				
<b>Customer Name</b>	Home Depot				
<b>Property Address</b>	1300 Park Center Drive				
<b>Customer Contact</b>	Terry Snowden				
<b>ECAD Status Retrofit – In Compliance</b>			<b>Total Measure Costs</b>	\$1,370,619	
			<b>Total Rebate – Not to Exceed</b>	\$197,259	
			<b>% of Total Measure Costs</b>	14%	

SCOPE OF WORK					
Measure	Rebate Amount	kW Saved - Estimated	kWh Saved - Estimated	Measure Cost	\$/kW
Custom DX to Chiller	\$132,652	442	1,673,182	\$787,220	\$300
Cooling Tower	\$4,162	17	40,534	\$500,242	\$250
VFDs	\$60,446	150	469,549	\$83,157	\$402
<b>Totals</b>	<b>\$197,259</b>	<b>609</b>	<b>2,183,265</b>	<b>\$1,370,619</b>	<b>\$324</b>

Previous Measures Performed in last 10 Years	Completion Date	Rebate Amount
Lighting and Lighting Controls	1/2012	\$9,060
Roofing Insulation	2/2012	\$17,955
Air Conditioning Replacement	9/2012	\$8,207

AE Commercial Energy Efficiency Program for FY2015 (as of July 2015)							
Program	kW Savings Goal	YTD kW Savings	% of Goal	Budget	YTD Dollars Spent	YTD Participation	\$/kW
Commercial Rebates	12,150	4,932	40.6%	\$3,500,000	\$1,525,566	254	\$309.32