



## COMMERCIAL REBATE FACT SHEET

### University of Texas at Austin

Property Name	University of Texas – J. J. Pickle Research Campus			
Customer Name	University of Texas at Austin			
Property Address	10000 Burnet Rd.			
Total Square Feet	819,660			
Year Built	1985			
Air Conditioner Total Tonnage	3,000			
Water Heater Type	Gas			
Total Project Costs	\$12,000,000			
Total Rebate – Not to Exceed	\$97,178			
% of Total Construction Costs	0.8%			
Note(s)				
The University of Texas at Austin installed the energy conservation measures listed below at their J. J. Pickle Research Campus, resulting in a rebate of \$97,177.90. The rebate will cover 0.8% of the total project cost of \$12,000,000.				
Project Annual Savings (Estimated)				
Kilowatt (kW)	321			
\$/kW	\$303			
Kilowatt-hours (kWh)	771,759			
Scope of Work				
Measure	Rebate Amount	kW Saved – Estimated	kWh Saved – Estimated	\$/kW
Variable Frequency Drives <sup>1</sup>	\$ 92,828	309	451,968	\$301
Water Cooled Centrifugal Chillers	\$ 4,350	12	319,791	\$372
Total	\$97,178	418	931,433	\$303
Measures Performed in last 10 years at this property	Completion Date		Rebate Amount	
None	N/A		N/A	

<sup>1</sup> Variable Frequency Drives (VFDs) adjust the speed of a pump or motor by varying its input frequency and voltage, thereby reducing its peak power when full speed is not required. VFDs are installed on chilled water pumps, condenser water pumps and domestic pumps.