



MEMORANDUM

To: Water and Wastewater Commissioners
From: Brett Ueno, Utility Development Services
Date: November 5, 2021
Subject: 8921 Hwy 290 West (Wastewater SER-4796)

Enclosed is additional technical information related to Wastewater SER-4796 and the associated Request for Council Action.

Other SERs:

- There are 5 wastewater SER applications located within one-half of a mile of the subject tract. Of these SERs, 3 were approved by City Council, 1 was administratively approved by Austin Water, and 1 was withdrawn.
- There are 6 water SER applications located within one-half of a mile of the subject tract. Of these SERs, 1 was approved by City Council, 2 were administratively approved by Austin Water, and 3 were withdrawn.

Water Utility Service:

- Water service will be provided by West Travis County Public Utility Agency.

Wastewater Utility Service:

- The City's existing wastewater collection system is located approximately 3,900 feet from the subject tract in Circle Dr.

SER Improvements:

- The SER improvements will cross Devil's Pen Creek. The improvements will be located along the US 290 Hwy right-of-way at this creek crossing.
- The SER improvements will conform to all applicable City Code requirements, be designed in accordance with City's Environmental Criteria Manual and Utilities Criteria Manual, and be inspected by the City's Development Services Department.

If you need additional information, please let me know. Thank you.

cc: Colleen Kirk, P.E., SER Program Supervising Engineer
Shwetha Pandurangi, P.E., Utility Development Services Division Manager
Kevin Critendon, P.E., Assistant Director
Greg Meszaros, Director

