



July 8, 2022

Jim Wittliff
1409 Possum Trot
Austin TX, 78703

Property Description: W 91.2 FT OF LOT 5 & NW 20X90 AV OF LOT 6 BLK 6 WESTFIELD A

Re: C15-2020-0038

Dear Jim,

Austin Energy (AE) has reviewed your application for the above referenced property, requesting that the Board of Adjustment consider a variance request from LDC Section 25-2-492 at 8114 Cache Drive.

Austin Energy does not oppose the request, provided that any proposed permanent structures meet 15' radial clearance from any existing overhead electric facilities. Also, any other proposed or existing improvements must adhere to Austin Energy's Clearance & Safety Criteria, the National Electric Safety Code, and OSHA requirements. Any removal or relocation of existing facilities will be at the owner's/applicant's expense.

Please use this link to be advised of our clearance and safety requirements which are additional conditions of the above review action:

https://library.municode.com/tx/austin/codes/utilities_criteria_manual?nodeId=S1AUENDECR_1.10.0CLSARE

If you require further information or have any questions regarding the above comments, please contact our office. Thank you for contacting Austin Energy.

Cody Shook, Planner II

Austin Energy
Public Involvement | Real Estate Services
2500 Montopolis Drive
Austin, TX 78741
(512) 322-6881
Cody.Shook@austinenergy.com