



August 31, 2022

Jaden Rodriguez
5213 Tucker Hill Ln
Cedar Creek, TX 78602

Property Description: ABS 797 SUR 5 WESTBROOK T B ACR 9.8026

Re: C16-2022-0005

Dear Jaden,

Austin Energy (AE) has reviewed your application for the above referenced property, requesting that the Board of Adjustment consider a variance request from LDC Section 25-10-130 at 7712 Elroy Road.

Austin Energy does not oppose the request, provided that the proposed sign follows Austin Energy's Clearance & Safety Criteria (**15' radial clearance from any existing overhead or underground electric facilities**), the National Electric Safety Code, and OSHA requirements. Any removal or relocation of existing facilities will be at the owner's/applicant's expense.

Please use this link to be advised of our clearance and safety requirements which are additional conditions of the above review action:

https://library.municode.com/tx/austin/codes/utilities_criteria_manual?nodeId=S1AUENDECR_1.10.0CLSARE

If you require further information or have any questions regarding the above comments, please contact our office. Thank you for contacting Austin Energy.

Cody Shook, Planner II

Austin Energy
Public Involvement | Real Estate Services
2500 Montopolis Drive
Austin, TX 78741
(512) 322-6881
Cody.Shook@austinenergy.com