



October 10, 2022

Nikelle Meade
111 Congress Ave, Ste 1400
Austin TX, 78701

Property Description: W 35.6FT OF N138FT OF W193.4 OLT 20 DIVISION O

Re: C15-2022-0061

Dear Nikelle,

Austin Energy (AE) has reviewed your application for the above referenced property, requesting that the Board of Adjustment consider a variance request from LDC Section 25-2-492 at 1401 E 3rd St.

Austin Energy cannot approve this variance request until plans have been reviewed and approved by AE's Transmission Engineering Department. Please send georeferenced CAD drawings for this project to Cody.Shook@austinenergy.com, along with any site plans or surveys you have showing the overhead electric transmission lines located along Navasota St. Any development on this site must meet Austin Energy's Clearance & Safety Criteria, the National Electric Safety Code, and OSHA requirements. Any removal or relocation of existing facilities will be at the owner's/applicant's expense.

Please use this link to be advised of our clearance and safety requirements which are additional conditions of the above review action:

https://library.municode.com/tx/austin/codes/utilities_criteria_manual?nodeId=S1AUENDECR_1.10.0CLSARE

If you require further information or have any questions regarding the above comments, please contact our office. Thank you for contacting Austin Energy.

Cody Shook, Planner II

Austin Energy
Public Involvement | Real Estate Services
2500 Montopolis Drive
Austin, TX 78741
(512) 322-6881
Cody.Shook@austinenergy.com