Austin Energy FY2023 Q2 Operations Update May 2023

Lisa Martin


Acting Deputy General Manager & Chief Operating Officer





Agenda

Quarterly
Operations
Update









Executive Summary



Generator availability on-target

For the quarter, resources met availability targets when considering planned outages



Reliability performance trending up

Performance over the longer term is trending negative, yet remains well above Texas utilities average



Renewable production on-target

For the quarter, 57% aggregate renewable production as a percentage of load



Carbon free production on-target

For the quarter, 84% carbon-free generation as a percentage of load



Austin Energy Operations Update Reliability Performance



Generator Commercial Availability

| | Target Seasonal | Commercial Availability Actuals (%) | |
|--------------------------|--|-------------------------------------|-----------------|
| Generation Resource | eration Resource Commercial % Availability | | Q2 FY23 AVG* |
| Sand Hill Combined Cycle | 95 | 75 | 99 |
| Fayette Units | 97 | 69 | 100 |
| South Texas Project | 100 | 81 | 92 |




^{*}Commercial Availability values reflect maintenance or refueling outages typical for this period


^{**}Commercial Availability reported last quarter was in error and has been corrected in the table above

Net Generation and Load Analysis FY 2023 Q2


POWER GENERATION COST BY FUEL TYPE




CURRENT & HISTORICAL Q2 SYSTEM PEAK DEMAND (MW)



LOAD VS. GENERATION (MWH)



POWER GENERATION AS PERCENT OF LOAD





Distribution System Reliability

CAIDI = Customer Average Interruption Duration Index

Average time to restore service

SAIDI = System Average Interruption Duration Index


Total duration of interruptions for the average customer, during a period of time


SAIFI = System Average Interruption Frequency Index

How often the average customer experiences a sustained interruption, over a period of time


MED = Major Event Days

AUSTIN ENERGY









System Reliability & Texas Utilities Average

| | Austin Energy | Texas Utilities Average |
|---|------------------|----------------------------|
| SAIDI - System average interruption duration index (outage minutes per customer per year) | 67.55 | 372.56 |
| SAIFI - System average interruption frequency index (number of outages per year per customer) | 0.87 | 1.81 |
| CAIDI - Customer average interruption duration index (in minutes per outage experienced) | 77.64 | 185.52 |




Note 1: Compares AE CY2022 with most recent available EIA data covering CY2021. AE CY2021 data: SAIDI 63.40, SAIFI 0.76, CAIDI 83.42

Note 2: All data excludes Major Event Days

Austin Energy Operations Update Environmental Performance



Carbon-Free Generation as a Percentage of Load





Austin Energy Operations Update Grid Resilience Strategic Goal



Grid Resilience Initiatives







Improve Distribution System Reliability

Identify, rank, and address feeder maintenance needs in areas historically impacted by outages. Identify, rank and address system needs in areas most susceptible to wildfire risk.

- Address Top Feeders in both Performance and Wildfire Criticality



<u>Transmission System of the Future</u>

As part of the 2030 resource plan, Austin Energy contracted for a transmission system study to investigate ways to achieve the plan's goals while mitigating the impacts of the loss of generation plants.

- Transmission System Assessment to be complete by June 2023





Customer Driven. Community Focused.

