#### SUBDIVISION REVIEW SHEET

**CASE NO.:** C8-2023-0144.0A **COMMISSION DATE**: September 5, 2023

**SUBDIVISION NAME:** Resubdivision of Lot 1 of the Resubdivision of Lot 1 of 290 & Parmer

ADDRESS: 10150 E US 290 Hwy Service Road WB

**APPLICANT**: Andrew Pastor (E290/Parmer Ltd.)

**AGENT:** Anthony Ennis (Kimley Horn)

**ZONING**: CH-CO (Commercial Highway) NEIGHBORHOOD PLAN: N/A

**AREA:** 1.762 acres **LOTS**: 2

**COUNTY**: Travis **DISTRICT**: 1

**WATERSHED**: Gilleland Creek

JURISDICTION: Full Purpose

**SIDEWALKS:** Sidewalks along E US 290 and E Parmer Ln shall be in place prior to the lots being occupied. Sidewalks along FM 734/Parmer Ln and US 290 are subject to approval of TxDOT.

VARIANCE: N/A.

#### **DEPARTMENT COMMENTS:**

The request is for the approval of Resubdivision of Lot 1 of the resubdivision of Lot 1 of 290 & Parmer, a resubdivision of Lot 1, 290 & Parmer Subdivision, comprised of 2 lots on 1.762 acres. This case includes an approved SER.

The plat does not comply with the criteria for approval in LDC 25-4-84(B) and staff recommends disapproval for the reasons listed in the attached comment report. An application that has been disapproved with reasons may be updated to address those reasons until the application expires. If the applicant submits an update to address the reasons for disapproval, that update will be presented to the Land Use Commission within fifteen days of submittal.

#### **STAFF RECOMMENDATION:**

Staff recommends disapproval of the plat for the reasons listed in the comment report dated August 30, 2023, and attached as Exhibit C.


CASE MANAGER: Nick Coussoulis PHONE: 512-978-1769

E-mail: nicholas.coussoulis@austintexas.gov

#### **ATTACHMENTS**

Exhibit A: Vicinity map Exhibit B: Proposed plat

Exhibit C: Comment report dated August 30, 2023



# **GRAPHIC SCALE IN FEET**

### **RESUBDIVISON OF LOT 1 OF THE RESUBDIVISION OF LOT 1 OF 290 & PARMER**

A 1.762 ACRE TRACT OF LAND, SITUATED IN THE CITY OF AUSTIN, LOCATED IN THE WILLIAM H. SANDERS SURVEY NO. 54, ABSTRACT 690, TRAVIS COUNTY, TEXAS AND BEING ALL OF A LOT 1, BLOCK A OF THE RESUBDIVISON OF LOT 1 OF 290 & PARMER SUBDIVISION OF RECORD IN DOCUMENT NO. 202200334 OF THE OFFICIAL PUBLIC RECORDS OF TRAVIS COUNTY, TEXAS.

> REMAINDER OF A CALLED 365.243 ACRES AUSTIN HB RESIDENTIAL PROPERTIES, LTD (VOL. 13100, PG. 1, O.P.R.)

> > WILLIAM H. SANDERS

SURVEY NO. 54 ABSTRACT 690

DRAINAGE RESTRICTIVE COVENANT

(DOC. NO. 2023044280)

<del>~</del>₹"IRON

LOT 2, BLOCK A

1.549 TOTAL ACRES

67,475 SQ FT.

290 & PARMER SUBDIVISION

WILLIAM H. SANDERS SURVEY NO. 54 ABSTRACT 690

E US 290 HWY SVRB WB

FOUND &

IRON ROD,

ALUMINUM

CAP, NO ID

 $\frac{1}{2}$ " IRON $\neg$ 

LOT 2, BLOCK A

80,934 SQ FT.

N65° 12' 29"E 183.44'

VARIABLE WIDTH

-WASTEWATER EASEMENT

(DOC. NO. 2023038810)

DRAINAGE RESTRICTIVE

(DOC. NO. 2023044280)

LOT 3, BLOCK A

1.073 TOTAL ACRES

46,740 SQ FT.

S65° 02' 59"W 184.33'

- COVENANT

VARIABLE WIDTH JOINT -USE ACCESS EASEMENT (DOC. NO. 2022177961)

121.95'

LOT 1B,

BLOCK A

0.705 TOTAL

**ACRES** 30,710 SQ FT.

LOT 1A, BLOCK A

/1.057 TOTAL ACRES

S65° 02' 59"W 402.57

46,043 SQ FT.

297.61

1.858 TOTAL ACRES

FOUND

TxDOT MONUMENT,

TYPE

LOT 4, BLOCK A

4.315 TOTAL ACRES

187,961 SQ FT.

DRAINAGE RESTRICTIVE COVENANT

(DOC. NO. 2023044280)

VARIABLE WIDTH JOINT USE ACCESS

EASEMENT (DOC. NO. 2023038811)

QT SOUTH LLC

(DOCUMENT NO. 2021263672, O.P.R.)

LOT 1, BLOCK A QUIKTRIP 4190 SUBDIVISION


(DOCUMENT NO. 202200053, O.P.R.)

SURVEY NO. 40 ABSTRACT 546

IRFC)

EASEMENT (DOC. NO. 2022177961)

VARIABLE WIDTH WASTEWATER



#### LOT SUMMARY

TOTAL LOT ACREAGE: 1.762

TOTAL SUBDIVISION ACREAGE: 1.762

TOTAL NUMBER OF LOTS: 2

#### **LEGEND**

1/2" IRON ROD W/ "MATKIN HOOVER

ENG. & SURVEY" CAP SET
1/2" IRON ROD FOUND W/ "ATWELL" CAP OFFICIAL PUBLIC RECORDS

B.M. ### BENCHMARK

— EXISTING PARCEL PROPERTY LINE - INTERNAL LOT LINE

ROAD CENTERLINE

#### **BENCHMARK**

E PARMER LN

VARIABLE WIDTH R.O.W.

(ROW CSJ. NO. 3417-03-005)

FOUND

TxDOT

rMONUMENX

TYPE

100

SET MAG NAIL IN CURB LINE OF E PARMER LANE ON NORTH SIDE OF SOUTHBOUND LANE BEARS S 61°58'15" E 398.12'

FROM THE NORTH CORNER OF THE SUBJECT TRACT.

ELEVATION: 527.61' (NAVD 88 DATUM FROM GPS)

SET MAG NAIL IN CURB LINE OF E PARMER LANE ON NORTH SIDE OF SOUTHBOUND LANE BEARS N 36°56'42" E 362.05' FROM THE SOUTHEAST CORNER OF THE

SUBJECT TRACT.

BEARING BASIS, ARE ON TEXAS STATE PLANE COORDINATE SYSTEM (CENTRAL ZONE 4203, NAD83).

ELEVATION: 526.62' (NAVD 88 DATUM FROM GPS)

LINE TABLE				
LINE#	LENGTH	BEARING		
L1	24.04'	N20° 12' 29"E		
L2	10.01'	S24° 47' 31"E		

CASE NO. C8-2022-0204.0A

5301 Southwest Parkway, Building 2, Suite 100 Austin Texas 78735

FIRM # 928 Checked by AJE/KP 06/16/2022

Tel. No. (512) 646-2237 068588051 1 OF 2

Copyright © 2022 Kimley-Horn and Associates, Inc.

**FOUND** 

§" IRON─ ROD

FOUND & IRON

ROD W/ TxDOT

ALUMÍNUM CAP

A 1.762 ACRE TRACT OF LAND, SITUATED IN THE CITY OF AUSTIN, LOCATED IN THE WILLIAM H. SANDERS SURVEY NO. 54, ABSTRACT 690, TRAVIS COUNTY, TEXAS AND BEING ALL OF A LOT 1, BLOCK A OF THE RESUBDIVISON OF LOT 1 OF 290 & PARMER SUBDIVISION OF RECORD IN DOCUMENT NO. 202200334 OF THE OFFICIAL PUBLIC RECORDS OF TRAVIS COUNTY, TEXAS.

STATE OF TEXAS
COUNTY OF TRAVIS

#### KNOW ALL MEN BY THESE PRESENTS:

THAT E290/PARMER, LTD. BEING OWNER OF A 1.762 ACRE TRACT OF LAND, SITUATED IN THE CITY OF AUSTIN, LOCATED IN THE WILLIAM H. SANDERS SURVEY NO.54, ABSTRACT 690, TRAVIS COUNTY, TEXAS AND BEING ALL OF A LOT 1, BLOCK A OF THE RESUBDIVISION OF LOT 1 OF 290 & PARMER, A SUBDIVISION OF RECORD IN DOCUMENT NO. 202200334 OF THE OFFICIAL PUBLIC RECORDS OF TRAVIS COUNTY, TEXAS, CONVEYED BY DEED OF RECORD NO.2013144303 AND NO.2013144302 OF THE REAL PROPERTY RECORDS OF TRAVIS COUNTY, TEXAS, AND SAID SUBDIVISION HAVING BEEN APPROVED FOR RESUBDIVISION PURSUANT TO THE PUBLIC NOTIFICATION AND HEARING PROVISIONS OF CHAPTER 212.014 OF THE LOCAL GOVERNMENT CODE, DO HEREBY RESUBDIVIDE 290 & PARMER IN ACCORDANCE WITH THE MAP OR PLAT ATTACHED HERETO, TO BE KNOWN AS:

#### RESUBDIVISION OF LOT 1 OF 290 & PARMER

AND DO HEREBY DEDICATE TO THE PUBLIC THE USE OF ALL STREETS AND EASEMENT SHOWN HEREON, SUBJECT TO ANY AND ALL EASEMENTS OR RESTRICTIONS HERETOFORE GRANTED AND NOT RELEASED.

WITNESS MY HAND THIS THE \_\_\_\_\_ DAY OF \_\_\_\_\_

E290/PARMER, LTD., A TEXAS LIMITED LIABILITY COMPANY

500 W 5TH STREET, SUITE 700, AUSTIN, TX 78701

CHRISTOPHER T. ELLIS

REGISTERED AGENT

STATE OF \_\_\_\_\_

BEFORE ME, THE UNDERSIGNED AUTHORITY, A NOTARY PUBLIC IN AND FOR THE STATE OF \_\_\_\_\_\_, ON THIS DAY DID PERSONALLY APPEAR \_\_\_\_\_\_, KNOWN TO BE THE PERSON WHOSE NAME IS SUBSCRIBED TO THE FOREGOING INSTRUMENT AND HAS ACKNOWLEDGED TO ME THAT THEY HAVE EXECUTED THE SAME FOR THE PURPOSE AND CONSIDERATION THEREIN EXPRESSED AND IN THE CAPACITY THEREIN STATED.

NOTARY PUBLIC - STATE OF \_\_\_\_\_\_ DATE

#### **GENERAL NOTES:**

- 1. THE WATER AND WASTEWATER UTILITY SYSTEM SERVING THIS SUBDIVISION MUST BE IN ACCORDANCE WITH THE CITY OF AUSTIN DESIGN CRITERIA. THE WATER AND WASTEWATER UTILITY PLAN MUST BE REVIEWED AND APPROVED BY THE AUSTIN WATER UTILITY. ALL WATER AND WASTEWATER CONSTRUCTION MUST BE INSPECTED BY THE CITY OF AUSTIN. THE LANDOWNER MUST PAY THE CITY INSPECTION FEE WITH THE UTILITY CONSTRUCTION.
- 2. PRIOR TO CONSTRUCTION, DRAINAGE PLANS WILL BE SUBMITTED TO THE CITY OF AUSTIN FOR REVIEW. RAINFALL RUNOFF SHALL BE HELD TO THE AMOUNT EXISTING AT UNDEVELOPED STATUS BY PONDING OR OTHER APPROVED METHODS.
- 3. NO BUILDINGS, FENCES, LANDSCAPING OR OTHER OBSTRUCTIONS ARE PERMITTED IN DRAINAGE EASEMENTS EXCEPT AS APPROVED BY THE CITY OF AUSTIN.
- 4. ALL DRAINAGE EASEMENTS ON PRIVATE PROPERTY SHALL BE MAINTAINED BY THE PROPERTY OWNER OR THEIR ASSIGNS UNLESS OTHERWISE DESCRIBED.
- 5. PROPERTY OWNER SHALL PROVIDE FOR ACCESS TO DRAINAGE EASEMENTS AS MAY BE NECESSARY AND SHALL NOT PROHIBIT ACCESS BY GOVERNMENTAL AUTHORITIES.
- 6. THE OWNER OF THIS SUBDIVISION AND THE OWNER'S SUCCESSORS AND ASSIGNS ARE RESPONSIBLE FOR CONSTRUCTION OF SUBDIVISION IMPROVEMENTS THAT COMPLY WITH CITY OF AUSTIN REGULATIONS. THE OWNER UNDERSTANDS THAT PLAT VACATION OR REPLATTING MAY BE REQUIRED, AT THE OWNER'S EXPENSE, IF PLANS TO CONSTRUCT THIS SUBDIVISION DO NOT COMPLY WITH THE REGULATIONS.
- 7. EROSION / SEDIMENTATION CONTROLS ARE REQUIRED FOR ALL CONSTRUCTION.
- 8. BY APPROVING THIS PLAT, THE CITY OF AUSTIN ASSUMES NO OBLIGATION TO CONSTRUCT ANY INFRASTRUCTURE IN CONNECTION WITH THIS SUBDIVISION. ANY SUBDIVISION INFRASTRUCTURE REQUIRED FOR THE DEVELOPMENT OF THE LOTS IN THIS SUBDIVISION IS THE RESPONSIBILITY OF THE DEVELOPER AND/OR THE OWNERS OF THE LOTS. FAILURE TO CONSTRUCT ANY REQUIRED INFRASTRUCTURE TO CITY STANDARDS MAY BE JUST CAUSE FOR THE CITY TO DENY APPLICATIONS FOR CERTAIN DEVELOPMENT PERMITS INCLUDING BUILDING PERMITS, SITE PLAN APPROVALS, AND/OR CERTIFICATES OF OCCUPANCY.
- 9. THE OWNER SHALL BE RESPONSIBLE FOR INSTALLATION OF TEMPORARY EROSION CONTROL, REVEGETATION AND TREE PROTECTION REQUIRED BY CITY ORDINANCE. IN ADDITION, THE OWNER SHALL BE RESPONSIBLE FOR ANY INITIAL TREE PRUNING THAT IS WITHIN TEN FEET OF THE CENTER LINE OF THE EXISTING OVERHEAD ELECTRICAL FACILITIES DESIGNED TO PROVIDE ELECTRIC SERVICE TO THIS PROJECT (IF ANY).
- 10. BLUEBONNET ELECTRIC COOPERATIVE HAS THE RIGHT TO PRUNE AND/OR REMOVE TREES, SHRUBBERY AND OTHER OBSTRUCTIONS TO THE EXTENT NECESSARY TO KEEP THE EASEMENTS CLEAR. BLUEBONNET ELECTRIC COOPERATIVE WILL PERFORM ALL TREE WORK IN COMPLIANCE WITH THE CITY OF AUSTIN LAND DEVELOPMENT CODE.
- 11. THE OWNER/DEVELOPER OF THIS SUBDIVISION/LOT SHALL PROVIDE BLUEBONNET ELECTRIC COOPERATIVE WITH ANY EASEMENT AND/OR ACCESS REQUIRED. IN ADDITION TO THOSE INDICATED, FOR THE INSTALLATION AND ONGOING MAINTENANCE OF OVERHEAD AND UNDERGROUND ELECTRIC FACILITIES. THESE EASEMENTS AND/OR ACCESS ARE REQUIRED TO PROVIDE ELECTRIC SERVICE TO THE BUILDING, AND WILL NOT BE LOCATED SO AS TO CAUSE THE SITE TO BE OUT OF COMPLIANCE WITH THE CITY OF AUSTIN LAND DEVELOPMENT CODE.
- 12. THE PLAT DOES NOT ALTER, AMEND OR REMOVE ANY EASEMENTS, COVENANTS OR RESTRICTIONS.
- 13. PUBLIC SIDEWALKS, BUILT TO CITY OF AUSTIN STANDARDS, ARE REQUIRED ALONG THE FOLLOWING STREETS AND AS SHOWN BY A DOTTED LINE ON THE FACE OF THE PLAT: E US 290 AND E PARMER LN. THESE SIDEWALKS SHALL BE IN PLACE PRIOR TO THE LOT BEING OCCUPIED. THE SIDEWALKS ALONG FM 734/PARMER LANE AND US 290 ARE SUBJECT TO THE APPROVAL OF THE TEXAS DEPT. OF TRANSPORTATION AT THE SITE PLAN PHASE. FAILURE TO CONSTRUCT THE REQUIRED SIDEWALKS MAY RESULT IN THE WITHHOLDING OF CERTIFICATES OF OCCUPANCY, BUILDING PERMITS, OR UTILITY CONNECTIONS BY THE GOVERNING BODY OR UTILITY COMPANY.
- 14. NO LOT SHALL BE OCCUPIED UNTIL THE STRUCTURE IS CONNECTED TO THE CITY OF AUSTIN WATER AND WASTEWATER UTILITY SYSTEM.
- 15. EACH LOT WITHIN THIS SUBDIVISION SHALL HAVE SEPARATE SEWER TAPS, SEPARATE WATER METERS, AND THEIR RESPECTIVE PRIVATE WATER AND SEWER LINES SHALL BE POSITIONED OR LOCATED IN A MANNER THAT WILL NOT CROSS LOT LINES
- 16. THE 100 YEAR FLOODPLAIN IS CONTAINED WITHIN THE DRAINAGE EASEMENT(S) SHOWN HEREON. NO PORTION OF THIS TRACT IS WITHIN THE BOUNDARIES OF THE 100 YEAR FLOOD PLAIN OF ANY WATERWAY THAT IS WITHIN THE LIMITS OF STUDY OF THE FEDERAL FLOOD INSURANCE ADMINISTRATION FIRM PANEL # 48453C0480J, DATED AUGUST 18,2014 FOR TRAVIS COUNTY."
- 17. VEHICULAR ACCESS TO E PARMER LN AND US 290 HWY IS SUBJECT TO THE APPROVAL OF THE TEXAS DEPARTMENT OF TRANSPORTATION AT THE SITE PLAN PHASE.
- 18. ALL RESTRICTIONS AND NOTES FROM THE PREVIOUS EXISTING SUBDIVSION 290 & PARMER RECORDED IN 202200102 OF THE PLAT RECORDS OF TRAVIS COUNTY, SHALL APPLY TO THIS PLAT.
- 19. WATER QUALITY CONTROLS ARE REQUIRED FOR ALL DEVELOPMENT PURSUANT TO THE LAND DEVELOPMENT CODE.
- 20. DEVELOPMENT OF STRUCTURES THAT REQUIRE A BUILDING PERMIT ON THIS PLAT WILL BE SUBJECT TO THE CITY OF AUSTIN STREET IMPACT FEE AS APPLICABLE PRIOR TO ACQUIRING THE BUILDING PERMIT.

#### SURVEYOR'S CERTIFICATION:

I, KYLE L. PRESSLER, AM AUTHORIZED UNDER THE LAWS OF THE STATE OF TEXAS TO PRACTICE THE PROFESSION OF SURVEYING AND HEREBY CERTIFY THAT THIS PLAT COMPLIES WITH THE SURVEYING RELATED PORTIONS OF TITLE 25 OF THE CITY OF AUSTIN LAND DEVELOPMENT CODE, AND IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE, AND WAS PREPARED FROM AN ACTUAL ON THE GROUND SURVEY OF THE PROPERTY MADE UNDER MY DIRECTION AND SUPERVISION ON APRIL 1, 2020.

KYLE L. PRESSLER, R.P.L.S.
REGISTERED PROFESSIONAL LAND
SURVEYOR NO. 6528 - STATE OF TEXAS
8 SPENCER ROAD, SUITE 300
BOERNE, TEXAS 78006
PH: 830-249-0600
FIRM NO. 10024000

#### ENGINEER'S CERTIFICATION:

I, ANTHONY J. ENNIS, AM AUTHORIZED UNDER THE LAWS OF THE STATE OF TEXAS TO PRACTICE THE PROFESSION OF ENGINEERING, AND HEREBY CERTIFY THAT THIS PLAT IS FEASIBLE FROM AN ENGINEERING STANDPOINT AND COMPLIES WITH THE ENGINEERING RELATED PORTIONS OF TITLE 25 OF THE CITY OF AUSTIN LAND DEVELOPMENT CODE, AND IS TRUE AND CORRECT TO THE BEST OF MY KNOWLEDGE.

NO PORTION OF THIS TRACT LIES WITHIN THE BOUNDARIES OF THE 100 YEAR FLOODPLAIN ACCORDING TO THE DATA FROM THE FEDERAL INSURANCE ADMINISTRATION FIRM PANEL NO. 48453C0480J, DATED AUGUST 18, 2014 FOR TRAVIS COUNTY, TEXAS.

ANTHONY J. ENNIS, P.E.
REGISTERED PROFESSIONAL ENGINEER No. 1256658
KIMLEY-HORN AND ASSOCIATES, INC.
5301 SOUTHWEST PARKWAY, BUILDING 2, SUITE 100
AUSTIN, TEXAS 78735
(512) 518-6260

THIS SUBDIVISION PLAT IS LOCATED WITHIN THE FULL PURPOSE JURISDICTION OF THE CITY OF AUSTIN ON THIS THE DAY OF . 20 . A.D.

APPROVED, ACCEPTED AND AUTHORIZED FOR RECORD BY THE DIRECTOR, DEVELOPMENT SERVICES DEPARTMENT, CITY OF AUSTIN, COUNTY OF TRAVIS, THIS THE DAY OF , 20 , A.D.

AMY COMBS, FOR:
DENISE LUCAS, DIRECTOR
DEVELOPMENT SERVICES DEPARTMENT

STATE OF TEXAS
COUNTY OF TRAVIS

I, REBECCA GUERRERO, CLERK OF TRAVIS COUNTY, TEXAS DO HEREBY CERTIFY THAT THE FOREGOING INSTRUMENT OF WRITING AND ITS CERTIFICATE OF AUTHENTICATION WAS FILED FOR RECORD IN MY OFFICE ON THE \_\_\_\_\_\_ DAY OF \_\_\_\_\_, 20\_\_\_, A.D. AT \_\_\_\_\_\_ O'CLOCK \_\_\_\_.M., DULY RECORDED ON THE \_\_\_\_\_\_ DAY OF \_\_\_\_\_, 20\_\_\_, A.D. AT \_\_\_\_\_\_ O'CLOCK \_\_\_\_.M., OF SAID COUNTY AND STATE IN DOCUMENT NUMBER OF THE OFFICIAL PUBLIC RECORDS OF TRAVIS COUNTY.

WITNESS MY HAND AND SEAL OF OFFICE OF THE COUNTY CLERK, THIS THE \_\_\_\_ DAY OF \_\_\_\_

DEPUTY, COUNTY CLERK

CASE NO. C8-2022-0204.0A

Kimley» Horn

5301 Southwest Parkway, Building 2, Suite Austin, Texas 78735 FIRM # 928

Scale Drawn by Checked by

NTS KB AJE/KP

 100
 Tel. No. (512) 646-2237

 8
 www.kimley-horn.com

 Date
 Project No.
 Sheet No.

 06/16/2022
 068588051
 2 OF 2

\_\_, 20\_\_\_, A.D.

Copyright © 2022 imley-Horn and Associates, Inc. All rights reserved

# WATER AND WASTEWATER SERVICE EXTENSION REQUEST FOR CONSIDERATION

Name: QuikTrip #4190		Service Requested: Wastewater				
SER-5124	Number 920669		Date Received: 05/17/2021			
Location: 9419 E PARMER LN AUSTI	N TX 78653 QuikTrip 4190	)				
Acres: 12.23			LUE: 153			
Alt. Utility Service or S.E.R. Number:	City of Austin water service	available				
Quad(s): S29 R29 R28	R29 R28 Reclaimed Pressure Zone: N/A			DDZ: YES		
Drainage Basin: GILLELAND	H		DWPZ: NO			
Flow (Estimated Peak Wet Weather): 109 GPM						
Cost Participation: \$0.00	% Within City Limits: 10	0	% Within Limited Purpose: 0			

#### Description of Improvements:

Applicant shall construct approximately 2,575 feet of 8-inch gravity wastewater main from the existing 18-inch wastewater interceptor (Project No. 2008-0587) located in E. Parmer Ln, and extend southeast along E. Parmer Ln. and then southwest along US Hwy 290 to the subject tract, as approximately shown on the attached map.

NOTES: 1) Wastewater flow based on engineering calculations received from Devin D. King, P.E. of Kimley-Horn and Associates, Inc. on 5/18/2021. 2) Depending on how the subject tract is ultimately developed, the proposed gravity wastewater main may be routed through the subject tract per Austin Water Pipeline Engineering approval.

## Approval of this Service Extension Request is subject to completion and acceptance of the improvements described above and the conditions set forth below:

- 1) Construction of all Service Extensions is subject to all environmental and planning ordinances.
- 2) Service Extensions are subject to the guidelines established in the Land Development Code, Chapter 25-9, Water and Wastewater Utility Service.
- 3) An approved Service Extension is not a reservation of capacity in the system, but is an acknowledgment of the intent to serve. Available capacity shall be confirmed at the time a development application is submitted.
- 4) The level of service approved by this document does not imply commitment for land use.
- 5) Public utility mains must meet City of Austin Design and Construction Criteria and must be approved by Austin Water Engineering Review.
- 6) Proposed public wastewater improvements will be dedicated to the City of Austin for ownership, operation, and maintenance.
- 7) Proposed public wastewater improvements must be placed in the public right-of-way or approved utility easements. Utility easements must be approved by Austin Water Engineering Review and must be in place prior to construction plan approval.

8) The approved Service Extension will automatically expire 180 days after date of approval unless a development application has been accepted by the Development Services Department. The Service Extension expires on the date the development expires, or if approved, on the date the development application approval expires.

11/5/2021

Project Manager, Utility Development Services

Date


11/06/2021

Asst. Director, Env., Planning, and Development Svcs.

Date

Director, Austir Water

Date



# CITY OF AUSTIN -DEVELOPMENT SERVICES DEPARTMENT SUBDIVISION APPLICATION - MASTER COMMENT REPORT

CASE NUMBER: C8-2023-0144.0A

UPDATE: U0

CASE MANAGER: Nicholas Coussoulis Email: Nicholas.Coussoulis@austintexas.gov

PROJECT NAME: Resubdivision of Lot 1 of the Resub of Lot 1 of 290 & Parmer

LOCATION: 10150 E US 290 HWY SVRD WB

SUBMITTAL DATE: August 7, 2023 FINAL REPORT DATE: August 30, 2023

#### STAFF REPORT:

This report includes all staff comments received to date concerning your most recent subdivision application submittal. The comments may include requirements, recommendations, or information. The requirements in this report must be addressed by an updated submittal. The subdivision application will be approved when all requirements from each review discipline have been addressed. If you have any questions, concerns or if you require additional information about this report, please contact your case manager at the phone number listed above or by using the contact information listed for each reviewer in this report.

Any change to the plan/plat shall not cause noncompliance with any applicable code or criteria. In addition, any change to the plat may trigger new comments.

#### UPDATE DEADLINE INFORMATION (LDC 25-4-56; 25-4-82):

All comments must be addressed by filing an updated submittal prior to the update deadline of **November 6, 2023.** Otherwise, the application will expire. If this date falls on a weekend or City of Austin holiday, the next City of Austin workday will be the deadline.

Extension of Review Period, Extension of Update Deadline and Tolling of Application Period do not apply to applications for preliminary plan, plat or subdivision construction plans (LDC 25-1-88; 25-1-89; 25-1-90).

#### UPDATE SUBMITTAL INSTRUCTIONS (LDC 25-1-83):

- 1. Applicants must submit an update through the intake submittal webform: https://www.austintexas.gov/page/subdivision-application-process
- 2. Your update must include the following items:
  - 1. The revised plat/plan in pdf format
  - 2. A letter that addresses each comment in the master comment report
- 3. Updates must be submitted on an approved submittal date. Refer to the submittal calendar for a list of approved submittal dates.

#### **REVIEWERS:**

Planner 1: Tiffany Turpen

Subdivision: Nicholas Coussoulis

AW Utility Development Services: Bradley Barron

#### 911 Addressing Review - Janny Phung - janny.phung@austintexas.gov

AD1: This plat review is cleared; however, any changes to street names, street name labels, or street layouts will require a new review.

NOTE: Tracts of land accessed only by means of dedicated easement will be assigned only one house number based upon the juncture of the easement with the named street. All tracts of land thus accessed will be assigned unit numbers based upon their relative location on the easement.

NOTE: Refer to the private easement naming criteria in the addressing standards

Note: A copy of the Addressing Standards is available online at: http://www.austintexas.gov/department/911-addressing

The standards applied to all new street names in Travis County can be found at this link: http://www.austintexas.gov/sites/default/files/files/Information Technology/911Addressing/Street Name Standards.pdf

§25-4-155

#### ATD Engineering Review - Daniil Kontsevoy - 512-978-1561

ATD 1. No comments.

Subdivision Review - Nicholas Coussoulis - Nicholas.Coussoulis@austintexas.gov

SR 1. This application was initially submitted on August 7, 2023 and is subject to the following deadlines (25-1-83; 30-1-113; 25-4-84; 30-2-84; 25-4-85):

- Update deadline: November 6, 2023
- Fiscal due: February 5, 2024
- All submitted for recording due: March 4, 2024

County of

- SR 2. Add Case # C8-2023-0144.0A in the bottom right hand corner of each sheet. 25-1-83
- SR 3. Provide a copy of the current, recorded deed for this property. 25-1-83
- SR 4. Please revise the following administrative City of Austin approval block: 25-1-83

	DEVELOPME		DEPA	AUTHORIZED ARTMENT, CITY , 20, AD.						
	Nick Coussou	lis for:								
	Jose Roig, Dir	ector								
	Development Services Department									
SR 5.	Revise the notary signature block as follows: 25-1-83									
	State of		§							

	on this day did personally appear, known to be the person whose name is subscribed to the foregoing instrument and has acknowledged to me that they have executed the same for the purpose and consideration therein expressed and in the capacity therein stated.						
	Notary Public – State of Date						
SR 6.	Add the Land Use Commission approval block as follows 25-1-83:						
	Accepted and authorized for record by the Land Use Commission of the City of Austin, Texas, on this, theday of20						
	Chair Secretary						
SR 7.	Modify the Travis County Clerk recordation block as shown: 25-1-83  STATE OF TEXAS  COUNTY OF TRAVIS  I, Dyana Limon-Mercado, Clerk of Travis County, Texas, do hereby certify that the foregoing instrument of writing and its certificate of authentication was filed for record in my office on the day of, 20, A.D., at o'clockM., duly recorded on the day of, 20, A.D., at o'clockM, of said County and State in Document Number of the Official Public Records of Travis County.  Witness my hand and seal of the office of the county clerk, this the day of 20, A.D.						
	Deputy, County Clerk Travis County, Texas  If fiscal is required, the fiscal <u>estimate</u> must be approved by the update deadline. Fiscal <u>posting</u> will occur during the plat recordation stage. The reviewer requesting fiscal will help coordinate with the City's fiscal office. 25-4-84(D)  Add/revise the fiscal note as applicable:						

- a. If fiscal is not required to be posted, add the following note: 25-1-83
  - "By approving this plat, the City of Austin assumes no obligation to construct any infrastructure in connection with this subdivision. Any subdivision infrastructure required for the development of the lots in this subdivision is the responsibility of the developer and/or the owners of the lots. Failure to construct any required infrastructure to City standards may be just cause for the City to deny applications for certain development permits including building permits, site plan approvals, and/or certificates of occupancy."
- b. If fiscal is required, add the following note. 25-1-83, 25-4-38, 25-4-84

f i i i i f
;
  -  }  }
t
•
nestes

AW Utility Development Services - Bradley Barron - 512-972-0078

Per Utility Criteria Manual Section 2, §25-4, §25-9:

Add the following note to the plat:

THE WATER AND/OR WASTEWATER EASEMENTS INDICATED ON THIS PLAT ARE FOR THE PURPOSE OF CONSTRUCTION, OPERATION, MAINTENANCE, REPAIR, REPLACEMENT, UPGRADE, DECOMMISSIONING AND REMOVAL OF WATER AND/OR WASTEWATER FACILITIES AND APPURTENANCES. NO OBJECTS, INCLUDING BUT NOT LIMITED TO, BUILDINGS, RETAINING WALLS, TREES OR OTHER STRUCTURES ARE PERMITTED IN WATER AND/OR WASTEWATER EASEMENTS EXCEPT AS APPROVED BY AUSTIN WATER.

PARD / Planning & Design Review - Justin Stewart - 512-974-9475

PARD approves.

**End of Master Comment Report**