

**Recommendation for Council Action – Backup  
Floodplain Variance Request – 1121 Ebert Ave**

**SUMMARY OF FINDINGS:**

1. THE DEVELOPMENT DOES NOT CAUSE ADVERSE FLOODING ON OTHER PROPERTY. The applicant's engineer certified that the proposed development does not result in additional adverse flooding impact on other properties.
2. NO SAFE ACCESS. The proposed development's access point to the right-of-way is located in the 100-year floodplain. The depth of water during a 100-year flood event at Ebert Avenue is 1 foot. First responder personnel and building occupants do not have safe access to and from the building during a 100-year flood event.
3. THE PROPOSED FINISHED FLOOR ELEVATION IS ABOVE THE MINIMUM REQUIRED ELEVATION. The finished floor of a proposed building within the 100-year floodplain is required to be a minimum of 2 feet above 100-year floodplain elevation. The applicant is proposing the finished floor to be 2.2 feet above the 100-year floodplain.
4. HARDSHIP CONDITIONS FOR THE PROPERTY DO EXIST. The lot is located entirely in the 100-year floodplain. The means of egress code regulation presents a hardship since safe access for the property cannot be achieved to a public right-of-way.

**APPLICABLE CODE AND VARIANCES REQUESTED**

- I. LDC Section 25-12-53, (Flood Loads), C.4 Means of Egress provides that normal access to a building shall be by direct connection with an area that is a minimum of one foot above the design flood elevation.

***VARIANCE REQUESTED:*** *The applicant requests a variance to Technical Code Section 25-12-53.C.4, to allow a residential building to be constructed without normal access, either vehicular or pedestrian, to an area that is a minimum of one foot above the design flood elevation. The depth of the 100-year floodplain on the property is 1 foot.*

- II. LDC Section 25-7-92 (A) and (B) Encroachment on Floodplain Prohibited prohibits encroachment of a building or parking area on the 25-year and 100-year floodplains.

***VARIANCE REQUESTED:*** *The applicant requests a variance to allow placement of a residential building within the 100-year floodplain of the main stem of the Tannehill Branch Creek.*

## PREREQUISITES FOR GRANTING VARIANCES AND FINDINGS:

Per LDC Section 25-12-54, Technical Codes, F.7 Conditions for issuance, variances shall only be issued upon consideration of the following prerequisites:

### PREREQUISITE

- 1) A technical showing of good and sufficient cause based on the unique characteristics of the size, configuration, or topography of the site.

*Insufficient causes for issuing a variance may include the following:*

- *Less than a drastic depreciation of property.*
- *Convenience of property owner.*
- *Circumstances of owner not land.*
- *To obtain better financial return.*
- *Property similar to others in neighborhood.*
- *Hardship created by owner's own actions.*

- 2) A determination that failure to grant the variance would result in exceptional hardship by rendering the lot undevelopable.

*The location of the floodplain on the property is a characteristic of the land. Hardship refers to the effect of the floodplain status of the land on its use; it does not refer to personal or financial circumstances of the current owner of the land. In fact, financial hardship, inconvenience, aesthetic considerations, physical handicaps, personal preferences or the disapproval of one's neighbors do not qualify as exceptional hardships. The applicant has the burden of proving exceptional hardship. FEMA advises that the reasons for granting floodplain management variances must be substantial and the proof compelling. The claimed hardship must be exceptional, unusual and peculiar to the property involved.*

- 3) A determination that granting of a variance would not result in increased flood heights, additional threats to public safety, extraordinary public expense, nor create nuisances, cause fraud on or victimization of the public or conflict with existing laws or ordinances.

### FINDING

- 1) **CONDITION IS MET.** The flat topography in this neighborhood and on this lot, cause the 100-year floodplain to be expansive, yet at a relatively shallow depth and low velocity. The proposed building will be constructed above the minimum requirements of the floodplain regulations.

- 2) **CONDITION IS MET.** The lack of safe access presents a hardship since safe access for the property cannot be achieved to a public right-of-way.

- 3) **CONDITION IS PARTIALLY MET.** The proposed development does not increase flood heights. The development does increase the public safety threat because a new building is proposed in the floodplain without safe access for the occupants and first responders.

4) A determination that the variance is the minimum necessary, considering the flood hazard, to afford relief.

*Relief is defined as respite from unnecessary hardship. Unnecessary hardship is defined as:*

- *Loss of all beneficial or productive use.*
- *Deprivation of reasonable return on property.*
- *Deprivation of all or any reasonable use.*
- *Rendering property valueless.*
- *Inability to develop property in compliance with the regulations.*
- *Reasonable use cannot be made consistent with the regulation.*

5) Notification to the applicant in writing over the signature of the building official that the issuance of a variance to construct a structure below the base flood level will result in increased premium rates for flood insurance, and that such construction below the base flood level increases risks to life and property.

4) **CONDITION IS MET.** The proposed building will have its finished floor a minimum of 2.2 feet above 100-year floodplain. The safe access variance request is the minimum necessary considering the flood hazard to afford relief.

5) **CONDITION IS MET.** The finished floor elevation of the proposed building will be a minimum of 2.2 feet above the 100-year floodplain elevation.