

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 11/01/2023 - 11/30/2023

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.7	Avg	9.7	Avg	9.6	
		Max	9.8	Max	9.7	Max	9.7	
		Min	9.7	Min	9.6	Min	9.6	
Total Alkalinity	mg/L as CaCO3	Avg	64	Avg	71	Avg	77	
		Max	74	Max	75	Max	82	
		Min	52	Min	68	Min	74	
Total Hardness	mg/L as CaCO3	Avg	100	Avg	108	Avg	109	
		Max	112	Max	114	Max	113	
		Min	87	Min	106	Min	105	
Total Solids	mg/L	Avg	215	Avg	242	Avg	244	
		Max	256	Max	262	Max	270	
		Min	186	Min	228	Min	222	
Total Chloramines	mg/L	Avg	2.70	Avg	2.54	Avg	2.74	
		Max	2.95	Max	2.65	Max	2.90	
		Min	2.45	Min	2.45	Min	2.55	
Total Organic Carbon	mg/L	Avg	2.86	Avg	2.88	Avg	2.92	
		Max	3.05	Max	2.93	Max	2.94	
		Min	2.58	Min	2.77	Min	2.90	
Conductivity	umhos/cm	Avg	359	Avg	381	Avg	430	
		Max	364	Max	381	Max	430	
		Min	354	Min	381	Min	430	
Total Trihalomethanes	ug/L	Avg	31.9	Avg	28.1	Avg	31.5	
		Max	32.3	Max	28.1	Max	31.5	
		Min	31.5	Min	28.1	Min	31.5	
Turbidity	NTU	Avg	.06	Avg	.03	Avg	.05	
		Max	.09	Max	.05	Max	.07	
		Min	.04	Min	.02	Min	.03	