

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 04/01/2021 and 04/30/2021

Parameter	Units	Davis WTP			Ullrich WTP			Handcox WTP
pH	SU	Avg	9.7	Avg	9.7	Avg	9.6	
		Max	9.8	Max	9.9	Max	9.7	
		Min	9.5	Min	9.6	Min	9.5	
Total Alkalinity	mg/L as CaCO3	Avg	65	Avg	60	Avg	74	
		Max	74	Max	64	Max	80	
		Min	59	Min	55	Min	71	
Total Hardness	mg/L as CaCO3	Avg	95	Avg	91	Avg	98	
		Max	103	Max	94	Max	104	
		Min	88	Min	83	Min	94	
Total Chloramines	mg/L	Avg	2.72	Avg	2.87	Avg	2.87	
		Max	2.75	Max	3.00	Max	3.05	
		Min	2.65	Min	2.65	Min	2.80	
Total Organic Carbon	mg/L	Avg	2.51	Avg	2.36	Avg	2.43	
		Max	2.75	Max	2.42	Max	2.46	
		Min	2.35	Min	2.25	Min	2.38	
Conductivity	umhos/cm	Avg	333	Avg	306	Avg	370	
		Max	334	Max	306	Max	370	
		Min	331	Min	306	Min	370	
Total Trihalomethanes	ug/L	Avg	25.2	Avg	25.8	Avg	*	
		Max	26.2	Max	25.8	Max	*	
		Min	24.2	Min	25.8	Min	*	
Turbidity	NTU	Avg	0.06	Avg	0.03	Avg	0.03	
		Max	0.11	Max	0.05	Max	0.06	
		Min	0.04	Min	0.02	Min	0.02	

Due to Covid-19 the number of parameters analyzed has been reduced effective 3-27-20.

* Handcox WTP was offline during monthly sampling event.