

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 03/01/2022 - 03/31/2022

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.6	Avg	9.6	Avg	9.6	
		Max	9.7	Max	9.8	Max	9.6	
		Min	9.6	Min	9.5	Min	9.5	
Total Alkalinity	mg/L as CaCO3	Avg	68	Avg	65	Avg	77	
		Max	72	Max	68	Max	82	
		Min	60	Min	62	Min	72	
Total Hardness	mg/L as CaCO3	Avg	105	Avg	103	Avg	101	
		Max	110	Max	106	Max	106	
		Min	95	Min	99	Min	96	
Total Solids	mg/L	Avg	212	Avg	225	Avg	209	
		Max	244	Max	256	Max	244	
		Min	180	Min	204	Min	182	
Total Chloramines	mg/L	Avg	2.90	Avg	2.77	Avg	2.84	
		Max	3.00	Max	2.90	Max	3.05	
		Min	2.75	Min	2.70	Min	2.65	
Total Organic Carbon	mg/L	Avg	2.46	Avg	2.27	Avg	2.40	
		Max	2.56	Max	2.33	Max	2.43	
		Min	2.35	Min	2.20	Min	2.36	
Conductivity	umhos/cm	Avg	342	Avg	343	Avg	371	
		Max	345	Max	343	Max	371	
		Min	338	Min	343	Min	371	
Total Trihalomethanes	ug/L	Avg	27.7	Avg	25.4	Avg	25.8	
		Max	28.5	Max	25.4	Max	25.8	
		Min	26.9	Min	25.4	Min	25.8	
Turbidity	NTU	Avg	.06	Avg	.03	Avg	.03	
		Max	.08	Max	.10	Max	.08	
		Min	.04	Min	.02	Min	.02	